



250 WATT
MH
MOGUL

Ballast bypassed for a 63 watt LED
Keystone expander



Tilt this fixture down
away from bedroom
windows

Tilt this fixture down
away from bedroom
windows



250 WATT
MH
MOGUL

6-Pole lights, special
timer controlled= 'on' at
dusk, 'off' at dawn
8-28-20 station requests
pole lights on all night due
to vandalism.

Tilt this fixture down
away from bedroom
windows



250 WATT
MH
MOGUL

Special Timer in
12'x12' j-box in electrical
room auto adjust for DST
and sun changes,
need bucket truck

Ballast bypassed for a 18 watt
LED bulb Medium base,
controlled by photocell / timeclock
-need an 6-8 ft ladder

70 watt MH clear bulb
controlled by override
on watchdesk,
photo cell / timeclock
and interior override
switch

Special Tork EPC1
5 VDC electronic
Photocell under
eave, only one for
entire station
Need 6' ladder

Station 2 site lights 12-22-20

This light has been
removed due to
firemen complaints
on shining in
bedroom windows

On watchdesk there
were 2 buttons for
overriding the pole
lights and 5 bldg.
lights outside.
Disconnected now,
because too confusing

Photocell override
switch in basement
electrical room.
Push override button
in basement timeclock
also for bulb check on
most lights. This
timeclock is also
battery backup.

All site lights
controlled by photocell
/ timeclock only.
Except north pole
lights, special timer in
bsmnt 12'x12' j-box.
House Capt. Request
3-2-15
Timer is battery
backup, needs new
batt ??

Apparatus bay interior lights have another
timer on them to keep them from coming on
automatically during daylight. Set for 8:00am
(on) to 4:00pm (off) -timer relay is normally
closed. Timer has battery backup, needs new
batteries about every 2 years. Timer is in
house control box in Micro Rack room.

All front
lights
controlled
by
photocell /
timeclock

RAB WP1 LED
30 watt wall
pack, 6'-8'
ladder

RAB WP2 LED 37 -
37 watt wall pack-
controlled by photocell
/ timeclock, 6-8 ft
ladder

Ballast
bypassed
for a 18
watt LED
bulb

Ballast bypassed
for 16.5 watt
LED bulb
Medium base, flag

Ballast
bypassed
for a 18
watt LED
bulb

70 watt MH clear bulb
controlled by photocell
/ timeclock and interior
override switch, 6'
ladder

RAB FF LED 18
floodlight with an
adjusting daylight
switch, with no
photocell, need 12'
tall ladder or bucket

Ballast bypassed for a
18 watt LED bulb
Medium base controlled
by photocell / timeclock
-need a 6-8 ft ladder

Ballast bypassed for 16.5 watt LED
bulb Medium base controlled by
photocell / timeclock
-Need bucket truck to climb on steel
overhang or extension ladder

NORTH